

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Tests Show Coliform Bacteria in Blue Sky Heights Wua Clancy Water

Our water system recently violated a drinking water standard. Although this is not an emergency, as our customers, you have a right to know what happened, what you should do, and what we are doing to correct this situation.

We routinely monitor for drinking water contaminants. We took two samples to test for the presence of coliform bacteria during January 2015. Both of our samples showed the presence of total coliform bacteria. The standard is that no more than 1 sample per month may do so.

What should I do?

- You do not need to boil your water or take other corrective actions. However, if you have specific health concerns, consult your doctor.
- People with severely compromised immune systems, infants, and some elderly may be at increased risk. These people should seek advice about drinking water from their health care providers. General guidelines on ways to lessen the risk of infection by microbes are available from EPA's Safe Drinking Water Hotline at 1-800-426-4791.

What does this mean?

This is not an emergency. If it had been you would have been notified immediately. Total coliform bacteria are generally not harmful themselves. *Coliforms are bacteria which are naturally present in the environment and are used as an indicator that other, potentially-harmful, bacteria may be present. Coliforms were found in more samples than allowed and this was a warning of potential problems.*

Usually, Coliforms are a sign that there could be a problem with the treatment or distribution system (pipes). Whenever we detect coliform bacteria in any sample, we conduct follow-up testing to see if other bacteria of greater concern, such as fecal coliform or *E. coli*, are present. We did not find any of these bacteria in our subsequent testing.

What is being done?

REPEATING SAMPLES, POSTED NOTICE ON PUBLIC BULLETIN BOARD AT THE MAILBOXES. [Describe corrective action.]

We are still detecting coliform bacteria. We will inform you when our sampling shows that no bacteria are present. We anticipate resolving the problem within 2 WEEKS [estimated time frame].

For more information, please contact Stanford B Becker at 461-5763 [phone number] or Blue Sky Heights WUA 2 Rock Ridge Dr, Clancy, MT 59634

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

This notice is being sent to you by Blue Sky Heights WUA Clancy
State Water System ID#: MT0000030

Date and Method Distributed: 1-21-15 PUBLIC BULLETIN BOARD

Water System Class: C
County: Jefferson

Monitoring Period: January 2015
Violation Date: January 21, 2015